

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR- NA5001

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

6210 & 6223 Electric Strikes

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test evidence:331144 Fire Test Evidence 334654	
Self closing ability 5.4 Door mass and closing force	Grade 8= 200Kg door mass with maximum 15N closing force	EN 14846: 2008
Annex A Fire/Smoke test requirements	NPD	
Durability of self closing 5.3.2 Durability of latch action	Grade C= 200,000 test cycles with no load on latchbolt	
Resistance to Fire E(integrity) I(insulation)(for fire doors) 5.5 Suitability for use on fire/smoke doors	Grade F= classification time greater than 120min	

Certificate of Constancy of Performance

2812-CPR- NA5001

Placed on the Market under the name of:

Allegion (UK) Ltd
35 Rocky Lane, Aston, Birmingham, West Midlands B6 5RQ

and produced in the manufacturing plant

B/068

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 14846:2008

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued on **08/12/2022** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the notified product certification body.

CE Marking certificate valid to: **31/03/2023**

ERO Project Reference: **ERO 034621 P 1410**



Paul Duggan
Certification Manager

CSF408-NL 7.0